



Government Of West Bengal
Office Of The Divisional Fire Officer, North Dinajpur
West Bengal Fire & Emergency Services
Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134

Memo no.:FSR/0125186230600179

Date: 30-10-2023

From:
Divisional Fire Officer, North Dinajpur
West Bengal Fire & Emergency Services

To: NETAJEE SUBHASH CHANDRA BOSE INSTITUTE OF EDUCATION
RATANPUR, BINDOL, RAIGANJ, UTTAR DINAJPUR

Sub: Fire Safety Certificate for the Existing construction of G+ 1 Storied Building in the name of NETAJEE SUBHASH CHANDRA BOSE INSTITUTE OF EDUCATION Under group of Educational, at the premises No: Plot no - 95, 100, J.L No - 41, Mouza - Ratanpur 4 no, Ratanpur, G.P - Bindol, P.O- Bindol, P.S - Raiganj, Dist - Uttardinajpur.

This is in reference to your application no. 0125189230600063 dated 25-10-2023 regarding the Fire Safety Certificate for the Existing construction of G+ 1 Storied Building in the name of NETAJEE SUBHASH CHANDRA BOSE INSTITUTE OF EDUCATION Under group of Educational, at the premises No: Plot no - 95, 100, J.L No - 41, Mouza - Ratanpur 4 no, Ratanpur, G.P - Bindol, P.O- Bindol, P.S - Raiganj, Dist - Uttardinajpur.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Term & Condition:-

1. Driveway / open space of the surrounding building must be free from any type of obstruction for easy movement of Fire Appliances / fire personnel at the time of exigency.
2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will be strictly maintaining.
3. Arrangements shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building by a Licensee agency and to keep those in perfectly good working condition all the times and it should be written in the register.
4. Adequate number of "NO SMOKING" boards should be displaying surrounding the premises.
5. Existing electrical wiring and installation of whole building should be carefully checking and maintenance regularly by a licensed electrician for any wear and tear at those, particularly wiring on false ceiling and ducts.
6. Closed circuit T.V system and Fire alarm panel will have to be install, which observes all floor of the building.
7. Regular mock fire practices and evacuation drill should be conducted periodically by participation of all the occupants of

the building and for this purpose a special crew should be formed.

8.The notice and drawing of Fire fighting installation and Evacuation from the entire floor of the building should be prepared and displayed at every conspicuous place of the building as per clause 5.5 of N.B code. Fire exit should be marked with fluorescent letter at every floor.

09.Direction sign of escape route should be displaced prominently (Auto glow type) at all conspicuous place of the building as per clause 5.5 of the N.B Code.

10.Transformer, DG and switch-gear room should be protecting with automatic CO2 or D.C.P. Fire extinguisher conforming I.S specification.

11.First Aid Firefighting system should be providing as per I.S specification.

12.All the Firefighting Extinguisher should be test once in a year.

13.If required the old Firefighting system should be replaced with new, the cables will be always laying in M.S conduit pipe continuously bonded to the earth.

14. Mock fire drill and evacuation drill should be done periodically with participation of all officers personnel and security guards.

15. A register for the recording of Mock fire drill, evacuation drill ,testing and checking of whole firefighting installation, electrical installation will be maintained & liable to produce the same to the authorized officer of this department on demand.

16. The Fire Safety Certificate is valid for three years and has to be renewed after every three years from the date of issue of this letter as per Govt. of West Bengal Vide Notification No-629_L Dated-17/04/2018.

17. Use of LPG Cylinder /Gas Bank:-In case of any cooking gas/ Gas bank, the same should be installed conforming serial No.4.1.5 & 4.1.6 of the aforesaid I:S code of practice & and after obtaining Fire Service license u/s 12 of W.B F.S(license) rules-2004

Note Below:-

This FSC is hereby issued conditionally, the applicant/building authority shall comply with the following as soon as possible and formally inform the Divisional Fire Officer, North Dinajpur Division, Raiganj.

(1)An external spiral staircase shall be provided in the building and shall connect with the first floor corridors/passages maintaining the prescribed travel distance.

(2) The automatic sprinkler installation shall be provided in all floor areas including car parking area in building, as per I.S 9972 and alarm to be incorporated along with the sprinkler system.

(3) This fire safety certificate has to be kept out of any court case or bank loan related to the building authority for their existing building and West Bengal Fire and Emergency Service shall have no liability in this regard.

Divisional Fire Officer, North Dinajpur
West Bengal Fire & Emergency Services